



# WASTEWATER TREATMENT SERVICE REPORT

Date: 8/9/2018

Customer: Customer X

Bond Representative: John T. Dunford

Address: 100 Hollywood Lane

Phone: XXX-XXX-XXXX

City/State: Richmond, VA

Copy: John Riggins

Attention: Skip Johnson

Copy: Operators

Copy:

## Operational DATA

|                    | <u>Flow gpm</u> |           | <u>pH</u>            | <u>Control</u> |        |
|--------------------|-----------------|-----------|----------------------|----------------|--------|
| DAF Flow           | 108             |           | Influent 7.47        | (5.5 - 8.0)    |        |
|                    |                 |           | Effluent 7.21        | (5.0 - 11.0)   |        |
| Recycle PSI        | 88              | (90 - 95) | DAF Rotameter (SCFH) | 70             |        |
| Days               | 30              |           | Influent TSS         | 2100           | Record |
|                    |                 |           | Effluent TSS         | 23             | <100   |
| Effluent Turbidity | 23.3            | NTUs      | TSS Removal Percent  | 98.9           | >90%   |

## Product Usage & Inventory

| <u>Product</u> |      | <u>ppm</u> | <u>Inventory</u> | <u>Usage</u> | <u>Daily Cost</u> | <u>Daily Usage</u> |
|----------------|------|------------|------------------|--------------|-------------------|--------------------|
| 400S           | Coag | 94         | 276              | 217          |                   | 7.2                |
| 2431-90B       | Floc | 10         | 28               | 37           |                   | 1.2                |
| 3211-50B       | Floc | 4          | 14               | 14           |                   | 0.5                |

### Notes:

- Influent and Effluent pH probes calibrated weekly.
- DAF is cleaned every two weeks.
- TSS is measured via DR900 test Photometric Method\* (Also called Nonfilterable Residue) - NOT REPORTABLE
- Influent TSS is diluted 5:1 (multiplied by 5) to read

## Service Visit Summary

Effluent water quality was excellent. Slightly adjusted recirc water line valve entering the main supply into the DAF to maintain 90 - 95 psi (was at 86) and minimize pump cavitation. Floc formation was excellent in first and second reaction tanks. Jar testing showed feed rates optimized. Sludge blanket on DAF looked very good. Bob replaced the pH probe rods for the influent and effluent recently. Appears to have made a big difference with maintaining control range and minimizing acid and caustic overfeeds. Keep up the great work.

Thank you for your business!

John T. Dunford, CWT



Effluent Water



Second  
Reaction/Floc Tank -  
excellent solids  
separation!



Sludge Blanket  
uniform on top